

TOWN OF SOUTHINGTON
Conservation Commission
Inland Wetland & Watercourses Agency

75 MAIN STREET, SOUTHINGTON, CT 06489

T. Albanese, Chairman
J. Sullivan, Vice Chairman
C. Borowy, Secretary
T. Cabata
J. DeMello, Sr.
D. Palmieri
W. Camp
R. Post, Alternate
G. Ali, Alternate

SOUTHINGTON INLAND WETLANDS & WATERCOURSES AGENCY
Special Meeting Minutes
Saturday, November 19th, 2011
9:00 AM

The Southington Inland Wetlands and Watercourses Agency held a Special On Site Meeting Saturday, November 19th, 2011 to review FF Application #231. Members in attendance were Chair Albanese, Cmmsr. Borowy, Cmmsr. Sullivan, Cmmsr. Cabata, Cmmsr. Palmieri and Alt. Cmmsrs. Post and Ali. A quorum was achieved at 9:00 a.m. Chair Albanese called the meeting to order at 9:00 a.m. Alt. Cmmsr. Post was seated for Cmmsr. Camp., Alt. Cmmsr. Ali was seated for Cmmsr. DeMello.

The Project Engineer from Tighe & Bond provided an overview of the project purpose and need. Commissioners walked around the existing pump station building and heard the various proposed improvements including having new base accesses to the structure 2' above the floodplain. Wetland flags were noted along the river and were established by a Soil Scientist. The existing building will be removed. The point was made that the existing rip-rap is to be moved upslope because on the plan its extent was depicted downslope and close to the wetland line. The Engineer stated that that portion of the plan needs to be revised to ensure preservation of the existing stabilized slope behind the building. Approx. 35 CY. of rip-rap will be used and movement of soil is to be limited on site. The stand of mature trees to the north adjacent to the stream by the bridge is to remain as there is sufficient rip-rap in the area. Dewatering will take place with a filter bag set-up on the northern side of the existing driveway on flat grassy area. All E&S controls will be in place prior to construction. The start of work is expected to be late Spring or early Summer 2012, they do not anticipate a long dewatering or construction process as the new structure will be pre-cast. A motion to Table the item was made by Cmmsr. Palmieri and Seconded by Cmmsr. Borowy with all in favor upon vote. A motion to adjourn passed with all in favor at 9:30 a.m.