

Karen Molloy

From: Jim Grappone
Sent: Wednesday, June 1, 2022 12:12 PM
To: David Lavallee; Maryellen Edwards; Karen Molloy
Subject: RE: SPR #1840 885 Queen ATM

Engineering comments:

- What are the existing height of the plaza light poles? The new pole height to the fixtures is approximately 28-feet.
- Include in Key Notes for #54 to also protect existing CB during construction.
- Provide bituminous concrete pavement detail.
- Missing Sheet A104.
- Does the existing stop sign for the current exit need to be relocated/modified? A new stop bar should be added at the existing isle exit.

Written responses to comments are required.

James A. Grappone, P.E.
Town of Southington
Assistant Town Engineer
John Weichsel Municipal Center
196 North Main Street
Southington, CT 06489
Phone: 860-276-6231
Fax: 860-628-8669

From: David Lavallee <lavalleed@southington.org>
Sent: Wednesday, June 1, 2022 11:21 AM
To: Maryellen Edwards <edwardsm@southington.org>; Karen Molloy <molloyk@southington.org>
Cc: Jim Grappone <grapponej@southington.org>
Subject: SPR #1840 885 Queen ATM