

TOWN OF SOUTHTON
Conservation Commission
Inland Wetland & Watercourses Agency

196 N. MAIN STREET. SOUTHTON, CT 06489

To: Southington Inland Wetlands & Watercourses Agency
From: David Lavalley; Environmental Land Use Planner/Assistant Town Planner *DL*
Re: IW #1287- Town of Southington Aircraft Road bridge(s) repair/replacement
Date: 12/18/20

The applicant is seeking approval for disturbance of wetlands, upland review area and minor floodplain impact for reconstruction of a pedestrian bridge and repairs to a stone arch culvert over the Q River for the Linear Trail expansion. Invasive plant/shrub species removal is also proposed along the new extension.

1. Is there a full E&S sheet beyond PMT-06?
2. Filter bag for dewatering should be on a level surface.
3. Please look for any hazard trees in the vicinity of the bank that could be addressed under this application.
4. All refueling of equipment should take place out of the upland review area.
5. A spill kit will be required on site for each piece of heavy equipment (oil booms, etc.).
6. If mechanical means of invasives removal result in significant earth disturbance within the upland review area, please overseed with a conservation mix and secure with either hydroseed or straw matting on slopes greater than 3:1 (hay will not be accepted).
7. Please respond in writing.