
From: Radziwon, Ken <kradziwon@Blcompanies.com>
Sent: Wednesday, January 13, 2021 5:07 PM
To: Jim Grappone
Cc: David Nourse; Sheila McDonald; David Lavallee
Subject: RE: IW #1287 Review Checklist - Aircraft Rd bridge(s) repair/replacement
Attachments: PMT14C5121 - Permit Plans (2021-01-13).pdf

EXTERNAL EMAIL: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Jim – We have updated the Permit Plans per the IW comments. Please see the attached revised Permit Plans (if that didn't work, please use the link below) to be submitted to IW.

Permit Plans:

<https://link.zixcentral.com/u/1110964c/2JFHPexV6xGPACH4O49hPQ?u=https%3A%2F%2Fblcompanies.sharefile.com%2Fd-s5d519047fd464942bacd7fd71cdf7a44>

Let me know if you have any additional comments or questions.

Thanks,

Ken

Ken Radziwon, PE
Project Manager - Transportation
Office: 860.760.1925 | Mobile: 860.681.5426

From: Jim Grappone <grapponej@southington.org>
Sent: Monday, January 4, 2021 3:12 PM
To: Radziwon, Ken <kradziwon@Blcompanies.com>
Cc: David Nourse <noursed@southington.org>; Sheila McDonald <mcdonalds@southington.org>; David Lavallee <lavalled@southington.org>
Subject: RE: IW #1287 Review Checklist - Aircraft Rd bridge(s) repair/replacement

Hi Ken, did you prepare responses to the attached checklist comments?

James A. Grappone, P.E.
Town of Southington
Assistant Town Engineer
John Weichsel Municipal Center
196 North Main Street
Southington, CT 06489
Phone: 860-276-6231
Fax: 860-628-8669

From: Radziwon, Ken <kradziwon@Blcompanies.com>
Sent: Monday, December 21, 2020 10:32 AM

To: Jim Grappone <grapponej@southington.org>
Cc: David Nourse <noursed@southington.org>
Subject: RE: IW #1287 Review Checklist - Aircraft Rd bridge(s) repair/replacement

EXTERNAL EMAIL: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Jim – Our models show that there will be NO increase to the floodplain. In-fact, our model shows a slight decrease in the floodplain, but not really enough to improve conditions or really be noticeable. That being said, similar to conditions today, the proposed bridge will overtop between the 10 & 50 year storm. Again, that is similar to existing conditions.

Let me know if this helps,

Ken

Ken Radziwon, PE
Project Manager - Transportation
Office: 860.760.1925 | Mobile: 860.681.5426

From: Jim Grappone <grapponej@southington.org>
Sent: Monday, December 21, 2020 9:10 AM
To: Radziwon, Ken <kradziwon@Blcompanies.com>
Cc: David Nourse <noursed@southington.org>
Subject: FW: IW #1287 Review Checklist - Aircraft Rd bridge(s) repair/replacement

Ken, please see below.

James A. Grappone, P.E.
Town of Southington
Assistant Town Engineer
John Weichsel Municipal Center
196 North Main Street
Southington, CT 06489
Phone: 860-276-6231
Fax: 860-628-8669

From: David Lavallee
Sent: Monday, December 21, 2020 8:54 AM
To: Sheila McDonald <mcdonalds@southington.org>; Annette Turnquist <turnquista@southington.org>
Cc: Jim Grappone <grapponej@southington.org>
Subject: RE: IW #1287 Review Checklist - Aircraft Rd bridge(s) repair/replacement

Please verify that there will not be an increase in floodplain elevation that would require an FF application- thanks.

From: Sheila McDonald
Sent: Friday, December 18, 2020 2:55 PM
To: Annette Turnquist <turnquista@southington.org>
Cc: David Lavallee <lavalleed@southington.org>; Jim Grappone <grapponej@southington.org>
Subject: IW #1287 Review Checklist - Aircraft Rd bridge(s) repair/replacement

Please see the attached IW review checklist.

Thank you,

*Sheila McDonald
Secretary, Planning & Zoning Dept.
Municipal Center
196 North Main Street
Southington, CT 06489
(860)276-6250
Fax (860)628-3511*

This message contains confidential information and is intended for the individual named. If you are not the addressee you should not disseminate, distribute or copy this e-mail. Please notify the sender immediately by e-mail if you have received this e-mail by mistake And delete this e-mail from your system.'

This message contains confidential information and is intended for the individual named. If you are not the addressee you should not disseminate, distribute or copy this e-mail. Please notify the sender immediately by e-mail if you have received this e-mail by mistake And delete this e-mail from your system.'