



**TOWN OF SOUTHTON
FIRE MARSHAL'S OFFICE**

Community Risk Reduction
310 North Main St., Southington, CT 06489
(860) 621-3202



SITE PLAN REVIEW STATUS

DATE: 2/16/21

TO: Town Planner

FROM: Fire Marshal's Office

RE: Plan # SPU 645, SPR1813 Fire Plan # 21.006

The plans submitted to our office for review have been:

Approved

Rejected

Address of Property: 1261 South Main St

Comments:

Additional Site Plans will be needed to
address the following concerns: Fire Apparatus
turning radius, fire hydrant locations and
curbs cuts. Also, after conversation with architect
all separate buildings will be sprinklered. FDC
connections will need to show on the submitted building plans.