



TOWN OF SOUTHTON FIRE MARSHAL'S OFFICE

Community Risk Reduction
310 North Main St., Southington, CT 06489
(860) 621-3202



SITE PLAN REVIEW STATUS

DATE: 2/27/23

TO: Town Planner

FROM: Fire Marshal's Office

RE: Plan # SPU #674

Fire Plan # 23.024

The plans submitted to our office for review have been:

Approved

Rejected

Address of Property: 1303 West St

Comments:

- Emergency Vehicle access will be needed
from West St to North side connecting
the main apartment complex Road w/ private
hydrant added at cross point. All private
hydrants on property must be maintained and
recorded to SFD annually