

Karen Molloy

From: Rob Phillips
Sent: Friday, April 30, 2021 3:43 PM
To: Karen Molloy
Subject: FW: Laning Street Pressure

For file

Robert A. Phillips, MS/MPA, AICP
Director of Planning and Community Development
John Weichsel Municipal Center
196 North Main Street, Southington, CT
P - 860-276-6248
F - 860-628-3511
phillipsr@southington.org

From: Jim Grappone
Sent: Thursday, April 29, 2021 3:50 PM
To: Damian Chuchro <dchuchro@southingtonwater.org>; Rob Phillips <phillipsr@southington.org>
Subject: RE: Laning Street Pressure

Ok; thank you for getting back to us so quickly!

James A. Grappone, P.E.
Town of Southington
Assistant Town Engineer
John Weichsel Municipal Center
196 North Main Street
Southington, CT 06489
Phone: 860-276-6231
Fax: 860-628-8669

From: Damian Chuchro <dchuchro@southingtonwater.org>
Sent: Thursday, April 29, 2021 3:24 PM

To: Jim Grappone <grapponej@southington.org>; Rob Phillips <phillipsr@southington.org>

Subject: RE: Laning Street Pressure

EXTERNAL EMAIL: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

It was off of the hydrant directly in front of the parcel. The topography showed it at around an elevation of 295'.

Damian Chuchro
Engineering Technician
[Southington Water Department](#)
605 West Queen Street
Southington, CT 06489
Office: 860-628-5593
Fax: 860-621-0491

From: Jim Grappone <grapponej@southington.org>

Sent: Thursday, April 29, 2021 3:22 PM

To: Damian Chuchro <dchuchro@southingtonwater.org>; Rob Phillips <phillipsr@southington.org>

Subject: RE: Laning Street Pressure

Thanks Damian. Where was the location of the test?

From: Damian Chuchro [<mailto:dchuchro@southingtonwater.org>]

Sent: Thursday, April 29, 2021 3:19 PM

To: Jim Grappone; Rob Phillips

Subject: Laning Street Pressure

EXTERNAL EMAIL: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Gentlemen,

We had a pressure reading taken at the hydrants on Laning Street and it looked to be between 52-60 psi which is more than adequate enough to serve the public. The state requires us to provide a minimum of 30 psi. Let me know if you need anything else.

Thank you,

Damian Chuchro
Engineering Technician
Southington Water Department
605 West Queen Street
Southington, CT 06489
Office: 860-628-5593
Fax: 860-621-0491

This message contains confidential information and is intended for the individual named. If you are not the addressee you should not disseminate, distribute or copy this e-mail. Please notify the sender immediately by e-mail if you have received this e-mail by mistake And delete this e-mail from your system.'