

TOWN OF SOUTHINGTON
PLANNING DEPARTMENT

SPR # 1839	File
------------	------

APPLICATION REFERRAL

22.098

PENDING BEFORE:

- ☒ Planning and Zoning Commission
- ☐ Zoning Board of Appeals
- ☐ Inland Wetlands & Watercourses Agency
- ☐ Other _____
- ☒ Public Hearing/Meeting Date: 5/17
- ☐ For your information
- ☐ Map return requested only if noted
- ☐ Please review for consideration of those concerns that are under your jurisdiction.

<input checked="" type="checkbox"/>	ENGINEER	With drainage rpt
<input checked="" type="checkbox"/>	ASSESSOR	Via email
<input checked="" type="checkbox"/>	WATER	
	POLICE DEPT	
<input checked="" type="checkbox"/>	FIRE DEPT	
<input checked="" type="checkbox"/>	ASSISTANT PLANNER	
<input checked="" type="checkbox"/>	HEALTH	
	CHIEF BUILDING OFFICIAL	
<input checked="" type="checkbox"/>	OTHER	Maryellen

FROM: Maryellen Edwards, Director of Planning and Community Development

DATE: 4/26/22 COMMENTS DUE: 5/10/22

RE: APPLICATION # SPR # 1839
17 West St

PROJECT DESCRIPTION Proposed 54 room hotel
22,620 sq +/-

REPLY

DATE: 5/10/22

Approved with condition that a fire hydrant is installed on the front of the property in line with the Fire Dept. Connection on the outside of the building for the Fire Sprinkler System.

[Signature]

5/10/22