

Karen Molloy

From: Jim Grappone
Sent: Tuesday, June 1, 2021 11:39 AM
To: Stephen Giudice (sgjudice@hecole.com)
Cc: David Lavallee; Rob Phillips; Karen Molloy; Annette Turnquist; Jennifer Montone
Subject: SPR#1819 - Sloper's Pond Improvements

Steve, I am sure there is plenty of time to address this comment, but my only concern is the capacity of the two existing 24" Town culverts in East Street that would receive the drawdown discharges (12" and 30" pipes) and the dewatering activity. There is probably some headwater that may assist in preventing water from overtopping onto East Street, but that should be verified before you are given DEEP/ACOE approval.

Thanks

James A. Grappone, P.E.
Town of Southington
Assistant Town Engineer
John Weichsel Municipal Center
196 North Main Street
Southington, CT 06489
Phone: 860-276-6231
Fax: 860-628-8669