



TOWN OF SOUTHINGTON FIRE MARSHAL'S OFFICE

Community Risk Reduction
310 North Main St., Southington, CT 06489
(860) 621-3202



SITE PLAN REVIEW STATUS

DATE: 5/20/21

TO: Town Planner
FROM: Fire Marshal's Office

RE: Plan # SPR 1821

Fire Plan # 21-071

The plans submitted to our office for review have been:

Approved

Rejected

Address of Property: 756 Main St

Comments:

Restaurant rear cooler must be all non-combustible siding due to placement within 10 ft of dumpster

Robert [Signature] 5/20/21

APPLICATION REFERRAL

21-071

PENDING BEFORE:

- Planning and Zoning Commission
- Zoning Board of Appeals
- Inland Wetlands & Watercourses Agency
- Other _____
- Public Hearing/Meeting Date: 6/1
- For your information

- Map return requested only if noted

- Please review for consideration of those concerns that are under your jurisdiction.

✓	ENGINEER	with drainage
✓	ASSESSOR	via email
✓	WATER	
	POLICE DEPT	
✓	FIRE DEPT	
✓	ASSISTANT PLANNER	
✓	HEALTH	
✓	CHIEF BUILDING OFFICIAL	
✓	OTHER	ROB

FROM: Robert A. Phillips, AICP, Director of Planning and Community Development

DATE: 5/12/21 COMMENTS DUE: 5/26/21

RE: APPLICATION # SPR # 1821
756 Main St

PROJECT DESCRIPTION Site plan mod for new restaurant building with walk-up and drive-thru pickup window service

REPLY SFP approved R. Hunt DATE: 5/26/21

Restaurant Proposed.

See attached notes on SFP form