

## **Karen Molloy**

---

**From:** Jim Grappone  
**Sent:** Tuesday, June 15, 2021 3:05 PM  
**To:** quirk@kratzertjones.com; Scott Fanning; Brian Plourde  
**Cc:** Karen Molloy; Rob Phillips; David Lavallee; Jennifer Montone; Annette Turnquist; Sev Bovino (bovino@kratzertjones.com)  
**Subject:** RE: Engineering comments - Dunkin - 756 Main Street SPR#1821

I have reviewed the revised plans and have the following comments:

- Provide a submittal for brick pavers/sidewalk and lighting conduit to match the Plantsville project (comment #3).
- Engineering reserves the right to require a 1,000 gallon exterior grease trap based on the use of the building (comment #5).
- Provide dumpster detail (dumpster pad detail shown – comment #15).

James A. Grappone, P.E.  
Town of Southington  
Assistant Town Engineer  
John Weichsel Municipal Center  
196 North Main Street  
Southington, CT 06489  
Phone: 860-276-6231  
Fax: 860-628-8669