

Karen Molloy

From: Jim Grappone
Sent: Thursday, September 16, 2021 9:38 AM
To: Maryellen Edwards
Cc: Karen Molloy; David Nourse; David Lavallee; Annette Turnquist; Sev Bovino (bovino@kratzertjones.com); 'Mike Tranquillo'; Jennifer Montone
Subject: RE: 202496-DECROCE SPR#1826

Here are my final comments to the revised plan:

- Is an underdrain needed at the base of the new driveway based on the highway slope?
- Designate "Drive-thru" and "Exit Lane" pavement markings in addition to the traffic arrows shown.
- Provide stop sign in the grass area (not the pavement) at the northeast corner by the corn flowers at the stop bar indicated.

James A. Grappone, P.E.
Town of Southington
Assistant Town Engineer
John Weichsel Municipal Center
196 North Main Street
Southington, CT 06489
Phone: 860-276-6231
Fax: 860-628-8669

From: Karen Molloy
Sent: Wednesday, September 15, 2021 12:05 PM
To: Jim Grappone <grapponej@southington.org>
Subject: FW: 202496-DECROCE

FYI – doesn't look like you were cc'd

From: David Lavallee
Sent: Wednesday, September 15, 2021 10:43 AM
To: Karen Molloy <molloyk@southington.org>
Subject: FW: 202496-DECROCE

From: Severino Bovino - VP, Land Planner - KJA <bovino@kratzertjones.com>
Sent: Wednesday, September 15, 2021 10:35 AM
To: Maryellen Edwards <edwardsm@southington.org>
Cc: David Lavallee <lavalleed@southington.org>
Subject: FW: 202496-DECROCE

EXTERNAL EMAIL: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.