



# TOWN OF SOUTHINGTON FIRE MARSHAL'S OFFICE

Community Risk Reduction  
310 North Main St., Southington, CT 06489  
(860) 621-3202



## SITE PLAN REVIEW STATUS

DATE: 10/14/21

TO: Town Planner

FROM: Fire Marshal's Office

RE: Plan # 5 1330

Fire Plan # 21-181

The plans submitted to our office for review have been:

Approved

Rejected

Address of Property: 136 CURTISS ST

Comments:

Industrial Park will require commercial occupancy  
fire hydrants every 300ft. and Fire Department Access  
around all buildings in submitted plans