



**TOWN OF SOUTHTON  
FIRE MARSHAL'S OFFICE**

Community Risk Reduction  
310 North Main St., Southington, CT 06489  
(860) 621-3202



**SITE PLAN REVIEW STATUS**

DATE: 11/20/20

TO: Town Planner

FROM: Fire Marshal's Office

RE: Plan # 1802

Fire Plan # 20.117

The plans submitted to our office for review have been:

Approved

Rejected

Address of Property: 1615 West St

Comments:

Plan accepted without fire protection provided  
building remains Retail / office building.  
Requirements for protection will have to be  
subject for change if occupancy proposed is changed.

**Save Lives • Stop Fires**